



120 East Davis Street
Fayette, MO 65248-1405
(660) 248-1911
www.inovatia.com

Date: 7/18/2023

RE: Drinking Water Lead Analysis
Facility: Callao

Date Received: 06/20/23
Time Received: 10:17
Relinquished by: Corrina Alley
Sampler: Corrina Alley

Chain of Custody Number: 23-0653

Enclosed please find results for the sample(s) received as described above. The values reported are in conformance with internal and method quality control guidelines.

If you have questions or need more information, please contact us.

Thank you for your interest in working with Inovatia Laboratories.

Sincerely,


Jennifer Vandelight
Quality Assurance

Note: Testing Performed by NELAC Facility E87688

Enclosures:
Chain of Custody Record(s)



Analysis Report

Total Lead by ICP-MS

Chain of Custody: 23-0653

Facility: Callao

Sample Matrix: Water

Method of Analysis: EPA 200.8

Laboratory Number	Customer Sample Number	Date Collected	Sample Type	Result ug/L (ppb)	Reporting Limit
235839	CA-101-BOIL-MTP-PS-001	6/20/2023	Draw	ND	1.0
235840	CA-101-ART-HS-PS-002	6/20/2023	Draw	ND	1.0
235841	CA-101-BSMNT-RRFB1-PS-003	6/20/2023	Draw	ND	1.0
235842	CA-101-BSMNT-RRFB2-PS-004	6/20/2023	Draw	ND	1.0
235843	CA-101-7AND8-HS-PS-005	6/20/2023	Draw	1.62	1.0
235844	CA-101-7AND8-SC PS-006	6/20/2023	Draw	ND	1.0
235845	CA-102-OFF-DW PS-007	6/20/2023	Draw	ND	1.0
235846	CA-102-OFF-DF PS-008	6/20/2023	Draw	ND	1.0
235847	CA-102-OFF-RRFG PS-009	6/20/2023	Draw	1.34	1.0
235848	CA-102-HMEC-FP1 PS-010	6/20/2023	Draw	4.88	1.0
235849	CA-102-HMEC-FP2 PS-011	6/20/2023	Draw	ND	1.0
235850	CA-102-KITCH-HS PS-012	6/20/2023	Draw	4.69	1.0
235851	CA-102-KITCH-FP1 PS-013	6/20/2023	Draw	2.25	1.0
235852	CA-102-KITCH-FP2 PS-014	6/20/2023	Draw	1.62	1.0
235853	CA-102-GYM-RRF PS-015	6/20/2023	Draw	ND	1.0
235854	CA103-LAND-HS PS-016	6/20/2023	Draw	1.14	1.0
235855	CA103-RM8-HS PS-017	6/20/2023	Draw	25.0	1.0



120 East Davis Street
 Fayette, MO 65248-1405
 (660) 248-1911
 www.inovatia.com

Contact Name: Bob Franklin
 Company Name: Get the Lead Out LLC
 Address: PO Box 118
 City, State, zip: Sturgeon, MO 65284
 Phone Number: 417-294-6112
 E-Mail: bobfranklin@gettheleadoutmo.us

Matrix: Water
 Grab/Composite: Grab
 Number of Containers: 17
 Preservation: HNO3

Facility: CALLAO
 Facility Address: 403 Pine Street P.O. Box A Callao, MO 63534-0205
 Facility Contact: Pamela Halstead

COC: 230653

Lab Number	Customer Sample Number	Date Collected	Time Collected	
1	235839	CA-101-BOIL-MTP-PS-001	6-20-2023	06:22
2	235840	CA-101-ART-HS-PS-002	6-20-2023	06:22
3	235841	CA-101-BSMNT-RRFB1-PS-003	6-20-2023	06:24
4	235842	CA-101-BSMNT-RRFB2-PS-004	6-20-2023	06:24
5	235843	CA-101-7AND8-HS-PS-005	6-20-2023	06:25
6	235844	CA-101-7AND8-SC PS-006	6-20-2023	06:25
7	235845	CA-102-OFF-DW PS-007	6-20-2023	06:27
8	235846	CA-102-OFF-DF PS-008	6-20-2023	06:27
9	235847	CA-102-OFF-RRFG PS-009	6-20-2023	06:28
10	235848	CA-102-HMEC-FP1 PS-010	6-20-2023	06:30
11	235849	CA-102-HMEC-FP2 PS-011	6-20-2023	06:30
12	235850	CA-102-KITCH-HS PS-012	6-20-2023	06:31
13	235851	CA-102-KITCH-FP1 PS-013	6-20-2023	06:31
14	235852	CA-102-KITCH-FP2 PS-014	6-20-2023	06:32
15	235853	CA-102-GYM-RRF PS-015	6-20-2023	06:33
16	235854	CA103-LAND-HS PS-016	6-20-2023	06:35
17	235855	CA103-RM8-HS PS-017	6-20-2023	06:35
18	235856	PS-018	6-20-2023	No sample
19	235857	PS-019	6-20-2023	↓
20	235858	PS-020	6-20-2023	↓

Delivery Method: Hand
 Coolant: ---
 Arrival Temperature: N/A

Sampler Signature: Carrina Alley

Date/Time: 06:40

Relinquished By: Carrina Alley

Date/Time: 6-20-2023

Received By: Spandhlicht

Date/Time: 2023/06/20 1017